



COPPER-FIN 2 MAINTENANCE INSPECTION REPORT

DATE	Check for leaks in gas/water lines	Check combustion air openings	Check air filter and replace as needed	Check Relief Valve	Check all wiring and connections	Check and clean fans	Inspect and clean HEX if needed	Inspect and clean burners if needed	Inspect HEX waterways	Check burner flame patterns
Recommended Inspection Intervals	Monthly	Monthly	Monthly	Monthly	Every Six Months	Every Six Months	Annually	Annually	Annually	Annually

MODEL # _____ SERIAL# _____ DATE UNIT INSTALLED _____

FOR TECHNICAL QUESTIONS WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL