



CREST MAINTENACE INSPECTION REPORT



DATE	Check vent and air pipe	Check relief valve	Check condensate drain system	Test low water cut-off and reset	Inspect interior and clean	Check for leaks water, air, flue and condensate	Check/clean condensate trap	Check igniter and flame sense rods	Check flame signal 1 and 2
Recommended inspection intervals	Monthly	Monthly	Monthly	Every Six Months	Annual	Annual	Annual	Annual	Annual
Model # _____	SERIAL # _____				DATE UNIT INSTALLED _____				