



EFFICIENCY PAC MAINTENANCE INSPECTION REPORT



DATE	Check for leaks in gas/water pipes	Check combustion air fan	Check relief valve	Check igniter	Inspect and clean burners	Inspect circulating pump	Inspect venting system for leaks	Inspect HEX waterways	Inspect and clean heat exchanger	Check burner flame pattern	Inspect tank for leaks
Recommended inspection intervals	Monthly	Every six months	Every six months	Every six months	Every six months	Every six months	Annually	Annually	Annually	Annually	Annually

MODEL # \_\_\_\_\_ SERIAL# \_\_\_\_\_ DATE UNIT INSTALLED \_\_\_\_\_

FOR TECHNICAL QUESTIONS. WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL