



INTELLI-FIN MAINTENANCE & SAFETY INSPECTION REPORT



DATE	Check vent and air piping	Check air and vent screens	Check auto air vents	Test low water and reset button	Check gas and water pipes for leaks	Check relief valve	Inspect and clean interior	Inspect and clean condensate trap	Check ignition and flame sense	Check flame signal	Inspect and clean HEX/ burners
Recommended Inspection Intervals	Monthly	Monthly	Monthly	Monthly	Every Six Months	Every Six Months	Annually	Annually	Annually	Annually	Annually

MODEL # _____ SERIAL# _____ DATE UNIT INSTALLED _____

FOR TECHNICAL QUESTIONS WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL