



KNIGHT XL MAINTENANCE INSPECTION REPORT



DATE	Inspect vent and air piping	Check air and vent screens	Check relief value	Check condensate drain system	Check boiler piping (gas and water) for leaks	Clean condensate trap and fill with fresh water	Check for leaks (water, gas, flue, air, condensate)	Check ignition and flame sense electrodes	Check wiring connections	Inspect flames and flame signal	Clean HEX, burner, and blower wheel as needed
Recommended Inspection Intervals	Monthly	Monthly	Monthly	Monthly	Every Six Months	Annually	Annually	Annually	Annually	Annually	Annually

MODEL # _____

SERIAL# _____

FOR TECHNICAL QUESTIONS WWW.LOCHINVAR.COM OR CALL TECHNICAL SUPPORT AT 1-800-722-2101
FOR DETAILED INSTRUCTIONS SEE I & O MANUAL