



SHIELD MAINTENANCE & SAFETY INSPECTION REPORT

DATE	Check vent and air piping	Check relief valve	Check condensate drain system	Clean condensate trap/fill with fresh water	Check Delta T	Check flame signal	Check for leaks in gas and water pipes	Check ignition and flame sense electrodes	Check anode rods	Clean HEX and burner
Recommended Inspection Intervals	Monthly	Monthly	Monthly	Annual	Monthly	Annual	Annual	Annual	Annual	Annual

MODEL # \_\_\_\_\_ SERIAL# \_\_\_\_\_ DATE UNIT INSTALLED \_\_\_\_\_

FOR TECH QUESTIONS WWW.LOCHINVAR.COM OR CALL TECH 1-800-722-2101

FOR DETAILED INSTRUCTIONS SEE I & O MANUAL